

MODEL:		TYPE
PROJECT:		
PREPARED BY:	DATE:	

SERIES SPECIFICATIONS

OMX SERIES

750 Lumen Emergency Fluorescent Ballast 120/277VAC with Time Delay












LINE DRAWING



CONSTRUCTION

Housing **Test Switch**

Durable painted steel construction in white finish with 2' LED illuminated test switch

flex conduit

Time Delay

Time delay to overcome end of life circuit protection

ELECTRICAL SPECIFICATIONS

Emergency Illumination Battery Recharge Time Battery Type

3.6V Rechargeable Ni-Cad Minimum 90 Minutes 24 Hours

LED Indicator Battery Discharge Time Frequency

Charge rate/power "ON" and push 50/60Hz 1.5 Hours

to test switch

Operating Temp. **Operating Voltage Output Lumens**

0°C ~ 50°C 750 Max. 120/277

Output **AC Output**





MODEL:		TYPE
PROJECT:		
PREPARED BY:	DATE:	

AMPERAGE/WATTAGE

CATALOC NUMBER	INPUT WATTS (W)		INPUT AMPS (A)	
CATALOG NUMBER	120V	277V	120V	277V
OMX6500ACTD	3.8	3.8	0.270	0.270

LAMP COMPATIBILITY

Compatible with most one-, two-, three-, and four-lamp electronic standard and dimming AC ballasts.

Operates one 25W-40W T8 through T12, one 13W-42W 4-pin compact or one 18W-40W 4-pin long compact fluorescent lamps. Refer to lamp compatibility chart for a complete list of lamps.

LAMP	WATTS	INITIAL LUMENS
		1-Lamp
T8	32	675
T12	40	650
4-Pin PL CF	13	450
4-Pin PL CF	18	500

WATTS	INITIAL LUMENS
	1-Lamp
26	575
32	675
42	750
	26

LAMP	WATTS	INITIAL LU- MENS
		1-Lamp
4-Pin Long CF	18	525
4-Pin Long CF	24	575
4-Pin Long CF	36	600
4-Pin Long CF	40	650

In 2-lamp operation, lumens are equally split between the two lamps

MOUNTING SPECIFICATIONS

Suitable for installation inside, on top or in remote* of the fixture

Can be used in both switched and unswitched fixtures

CERTIFICATIONS/WARRANTY

Listing

UL Listed for factory or field installation

Compliance

Meets UL924, cULus, NFPA 101 Life Safety Code, NEC, OSHA, Local and State Codes.

Location Rating:

Suitable for damp locations.

Warranty

Guaranteed for five years from the purchase date of the product, against mechanical defects in manufacturing.





MODEL:		TYPE
PROJECT:		
PREPARED BY :	DATE:	

ORDERING INFORMATION

Sample Part Number: OMX6500-ACTD

ОМХ	6500	-ACTD
SERIES	LUMENS	OPTION
OMX	[6500] : 750 Lumens	[-ACTD] : Time Delay

NOTES

*When battery packs are remote mounted, the remote distance cannot exceed 1/2 of the distance from ballast to lamp specified by the A.C. ballast manufacturer. The maximum allowable remote mounting distance is 50 feet.